



LISTING INFORMATION OF Coopers Fire Ltd. FireMaster Smoke Barrier (with or without Hook & Loop)

SPEC ID: 27985

Coopers Fire Ltd.
Edward House
Penner Road
Havant, Hampshire, P09 1QZ
United Kingdom

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Coopers Fire Ltd. FireMaster Smoke Barrier (with or without Hook & Loop fastened passage) protective curtain assembly, Model Evacu8 D200E, for use in fire rated steel stud/gypsum or masonry wall applications.

Maximum Size: 13' wide x 11' high (oversize certificates available)

Maximum Hook & Loop length: 8' 0"

Qualified per UL 1784 (Smoke - brush type, number and length must be adhered to per test results.)

<u>Attribute</u>	<u>Value</u>
CSI Code	08 30 00 Specialty Doors and Frames
Listed or Inspected	LISTED
Report Number	1003767MID-001
Criteria	UL 1784 (2004)
Intertek Services	Certification
Listing Section	SMOKE CONTROL DOOR ASSEMBLIES
Verification Testing	YES
Verification Test Type	FTIR